



Municipal Council Kandri(Knhan)

Tah-Parshioni, Dist-Nagpur 441401

Email: nagrpanchayatkandri@gmail.com



Outward NO./ N.P.Kandri(Kanhan)/Fire Dept./ 173/2026

Date:- 17/04/2026

To,

**Elam Vachchhala Gopi Foundation,
Vachchhala Gopi Public School,
Behind Patil Nagar Ward No.5, Kandri-Kanhan.**

Subject : Regarding issuance of Fire Safety Compliance Certificate (NOC) for Vachchhalagopi Public School Building.

Reference: 1. Your application no. 5812 dated 18/02/2026
2. B-Form submitted by Karma Fire Protection L.L.P , Mumbai, bearing License No. MFS/LA/RF- 226 /RD-221 dated 24/03/2026

In accordance with the above-mentioned reference application, you have installed all fire safety equipment in the school building as per the audit report B-Form of Karma Fire Protection L.L.P , Mumbai. And as per reference number (1), the Additional Fire Officer has inspected your building on 09/04/2026 at 02:21 pm and since the fire safety related materials are available, you are hereby granted renewal of regular No Objection Certificate subject to the following terms and conditions.

Terms and Conditions

- 1) The building must be constructed as per the National Building Code 2016.
- 2) Maharashtra Fire Prevention and Life Safety Measures Act 2006 Rules and Regulations and National Building Code 2018 Part 4, if the law is not strictly followed, action will be taken as per the rules.
- 3) After conducting a security check by an authorized agency, the village must complete the resolution of the errors mentioned in Appendix-One and Appendix-Two within the above prescribed period and submit a letter to the office regarding the same.
- 4) Various types of fire fighting equipment must be installed. Eg. CO2, DCP Extinguisher, Fire Buckets, Automatic Alarm System, Smoke Detector, Hose-reel, Hydrant etc.
- 5) All types of installed firefighting equipment should be of excellent quality and easily accessible in case of emergency.
- 6) Hose reel system must be on every floor of the building.

- 7) A roof-top water storage tank with a capacity of at least 25,000 liters should be available and always filled for fire extinguishing.
- 8) There must be at least one yard of plumbing on each floor.
- 9) There must be a separate parking arrangement within the building premises.
- 10) A board with emergency telephone numbers must be placed in a visible area and a board with fire safety signs must be placed in the interior of the building, visible even in the dark. "DANGER", "NO-SMOKING", "FIRE EXIT", "FIRE ESCAPE", "EXTINGUISHER", "EVACUATION PLAN", "FLOOR PLAN"
- 12) As per Section 4.6.2 of the National Building Code 2016 Part 8, a building with a height of 15 meters and above and an area of 1500 square meters must have at least two staircases.
- 13) A diesel and electric water pump is required.
- 14) Fire-resistant doors as well as emergency exits (FIRE EXIT) and "PUSH BAR TO OPEN" doors must be provided.
- 15) It will be mandatory to give written notice to the fire department in case of any changes in the building.
- 16) It is prohibited to use the lift beyond its capacity and in emergency situations. A LICENCE TO WORK LIFT will have to be presented.
- 17) In case of a failure of the main power supply to operate the lift, it is necessary to have an additional power system and an automatic system for an emergency diesel generator.
- 18) If unauthorized construction is found in the said property, the certificate in this regard will be considered as STA.
- 19) Training in the use of fire-fighting equipment should be provided to your employees regularly and from time to time.
- 20) The license obtained from the government should be renewed regularly every year.
- 21) After fulfilling the above, it is necessary to submit Form A as per the rules and regulations of Maharashtra Fire Prevention and Life Safety Measures Act 2006 (2009) and Form B in the months of January and July of every year.
- 22) Strictly follow the terms and conditions laid down by the government from time to time. The certificate being issued is temporary in nature and cannot be used for any other government work other than this work. If found to be so, the certificate in question should be considered invalid.

A Renewal of Fire Safety No Objection Certificate is being issued subject to the above mentioned terms and conditions. If the necessary compliance is not completed within the prescribed period, the said certificate will be deemed to be cancelled.

Note - This certificate will remain valid till 31st March 2027.



Fire Officer

Nagar Panchayt Kandri(Kanhan)